PROPOSED AMENDED RULES 1147 AND 1100 WORKING GROUP MEETING #8

MARCH 10, 2021 SOUTH COAST AQMD DIAMOND BAR, CA Zoom Meeting: https://scaqmd.zoom.us/j/91386076148

Meeting ID: 913 8607 6148 **Passcode:** 053701

Conference Call: 1 (669) 900-6833

AGENDA

- □ Summary of Previous Working Group
- ☐ Proposed Implementation Approach
- Status of BARCT Assessment
- □ Cost-Effectiveness Analysis
 - > Absorption Chillers
 - Microturbines (Distillate Fuel/Natural Gas)
 - Diesel Tar Pot
- Next Steps



PREVIOUS WORKING GROUP RECAP

Working Group #7

- Presented cost-effectiveness analysis for:
 - Afterburner, Thermal Oxidizer, RTO, and Oxidizer
 - Evaporator, Fryer, Heated Process Tank, and Parts Washer
 - Burn-off Furnace, Burnout Oven, Incinerator, Crematory with or without Integrated Afterburner
 - Tenter Frame, Fabric or Carpet Dryer

3

PROPOSED IMPLEMENTATION APPROACH

Overview of Existing Rule 1147 Implementation Approach

- ☐ The current approach for Rule 1147 is to have "units" comply with rule limits based on the daily emissions and unit age
 - Units with NOx emissions ≥1 pound per day are required to comply when unit is 15 years old
 - Units with NOx emissions <1 pound per day are required to comply when unit is 35 years old
 - > Option to allow continued operation with biennial testing
- □Units are required to comply with rule limit by July 1 of the year unit meets age requirements and submit permit applications by December 1 of the year prior

5

Overview of Proposed Implementation Approach

- □ Staff is proposing an implementation approach for RECLAIM and non-RECLAIM facilities, that is generally modeled after existing Rule 1147
- Two implementation schedules
 - All units, except low-emitting or near-limit units, must submit permit applications to meet the proposed NOx and CO limits when the burner reaches 12 years
 - Low-emitting or near-limit units must submit permit applications to meet the proposed NOx and CO limits when the burner reaches 32 years
- Regardless of the implementation schedule, the proposed NOx and CO limits must be met if there is a combustion system modification, combustion system or burner replacement, unit relocation, or unit replacement
- □ Units that meet the proposed NOx and CO limits through a source test will not be required to replace their burner; however, operators may need to modify their permit to reflect the proposed BARCT limit

Proposed Compliance for Units Subject to 12 Year Provisions

- □ When the burner reaches 12 years, the operator must:
 - By the following January 1st, submit a permit application to meet the proposed NOx and CO limits
 - Meet proposed NOx and CO limits 12 months after the permit to construct is issued
- Assuming an 18-month permit approval process, operators must meet the proposed NOx and CO limits when the burner is about 15 years old – similar to the 15 years allowed under Rule 1147
- Basing this provision on burner age instead of unit age ensures that all units meet the proposed NOx and CO limits
- □ The "two-step" implementation ensures that the operator has the full
 12 months to meet the proposed NOx and CO limits once permit to construct is issued

7


Proposed Compliance for Units Subject to 32 Year Provisions


- PAR 1147 expands this concept for low-emitting units to also include units that are near the proposed NOx limit referred to as "near-limit units"
- ☐ For low-emitting and near-limit units, when the burner reaches 32 years the operator must:
 - First: Submit a permit application to meet the proposed NOx and CO limits (6 months to submit permit application)
 - Second: Meet proposed NOx and CO limits 12 months after the permit to construct is issued
- □ Requiring operators to meet the proposed NOx and CO limits when the burner about 35 years old is similar to the 35 years allowed under Rule 1147
- □ The "two-step" implementation ensures that the operator has the full 12 months to meet the proposed NOx and CO limits once a permit to construct is issued


Defining Low-Emitting and Near-Limit Units Subject to 32 Year Provision

- □ PAR 1147 will use the same threshold as existing Rule 1147 for defining lowemitting units at < 1 lb/day</p>
 - Units that qualify as low-emitting to meet proposed NOx and CO limits when the burner reaches 35 years
- □ Propose near-limit units with a permit limit at or below existing Rule 1147 limits
 - This approach will address units with high cost-effectiveness values, but still requires that operators to meet the proposed NOx limit when the burner reaches 35 years
 - Use of a near-limit provision may also include other conditions such as limiting annual capacity factor¹ to address higher use units that are near limit and costeffective to meet the proposed NOx emission limit

¹ Annual capacity factor threshold will be calculated per equipment category







Summary of Implementation Approach for RECLAIM and Non-RECLAIM

Applicability	Implementation		
All Units (Except Low-Emitting and Near Limit Units)	 Beginning July 1, 2021 and every July thereafter, when a burner reaches 12 years submit a permit application by January 1st of the following calendar year that the burner reaches 12 years Must meet proposed NOx and CO limit 12 months after Permit to Construct is issued 		
<u>Low-Emitting Units</u> Unit with NOx emissions below 1 lb/day	 Beginning July 1, 2021 and every July thereafter, when a burner reaches 32 years submit a permit application by January 1st of the following calendar years 		
Near-Limit Units Unit with permit limit meeting existing Rule 1147 Limit with low annual capacity factor ¹	 that the burner reaches 32 years Must meet proposed NOx and CO limit 12 months after Permit to Construct is issued 		
All Units	 Regardless of the implementation schedule above, operators must meet proposed NOx limit if there is a combustion system modification, combustion system or burner replacement, unit relocation, or unit replacement Regardless of the implementation schedule above, operators must meet proposed CO limit at the time of meeting proposed NOx limit 		


Cost-Effectiveness Analysis


STATUS OF BARCT ASSESSMENT

15

PROGRESS OF RULE 1147 BARCT ASSESSMENT

- As of Previous Working group meeting:
 - Technology Assessment has been completed for both existing Rule 1147 categories and new proposed categories
 - Cost-effectiveness analysis is in progress with six categories completed and analysis of six additional categories remaining






STATUS SUMMARY C	F BARC	T ASSES:	SMENT		Cost-Effecti	veness Analysis
Equipment Category	Equipment Size	Operating Temperature	Current Rule Limit [^]	Initial BARCT Limit^	Cost- Effectiveness*	Proposed BARCT Limit
Oven, Dehydrator, Dryer, Heater, Kiln, Calciner, Cooker, Roaster, Furnace, or Heated Storage Tank	<40 MM/Dtm/hm	<1,200°F	30 ppm	20 ppm	\$12,700/Ton	20 ppm
	<40 MMBtu/hr	≥1,200°F	60 ppm	30 ppm	\$5,600/Ton	30 ppm
	≥40 MMBtu/hr	<1,200°F	30 ppm	5 ppm	Pending	
		≥1,200°F	60 ppm	5 ppm	Pending	
Afterburner, Degassing Unit, Remediation Unit, Thermal Oxidizer, Catalytic Oxidizer or Vapor Incinerator	All	All	60 ppm	20 ppm	\$12,300/Ton	20 ppm
Evaporator, Fryer, Heated Process Tank, and Parts Washer	All	All	60 ppm	30 ppm	\$31,300/Ton	60 ppm
Burn-off Furnace, Burnout Oven, Incinerator, Crematory with or without Integrated Afterburner	All	All	60 ppm	30 ppm	\$25,800/Ton	30 ppm
Tenter Frame, Fabric or Carpet Dryer	All	All	30 ppm	20 ppm	\$23,600/Ton	20 ppm
Other Unit and Process	All	<1,200°F	30 ppm		Pending	

STATUS SI (CONT'D)	JMMAR'	Y OF BAF	RCT ASS	ESSMENT	- Cost-Eff	ectiveness Analysis
Equipment Category	Equipment Size	Operating Temperature	Current Rule Limit [^]	Initial BARCT Limit	Cost- Effectiveness	Proposed BARCT Limit [^]
Absorption Chillers	All	All	30 ppm	20 ppm	Pen	ding
Micro-Turbines (Natural Gas)	All	All	N/A	9 ppm^	Pen	ding
Micro-Turbines (Distillate Fuel)	All	All	40 ppm	77 ppm^	Pending	
Auto-Claves	All	All	30 ppm	30 ppm	Pen	ding
All Liquid Fuel-	All	<1,200°F	40 ppm	40 ppm	Pen	ding
Fired Units	All	≥1,200°F	60 ppm	60 ppm	Pen	ding


Cost-Effectiveness Analysis


COST-EFFECTIVENESS ANALYSIS


Absorption Chillers



ABSORPTION CHILLERS BACKGROUND Current Rule 1147 limit for the "other" category is 30 to 60 ppm depending on process temperature Staff is proposing a separate category for absorption chillers within Rule 1147









MICROTURBINES (DISTILLATE FUEL) Microturbines <0.3 MW are not currently regulated in any South Coast AQMD Rule Distillate fuel microturbines are currently under the "liquid fuel" category in Rule 1147 Staff's proposal will create a new Rule 1147 category for liquid fuel-fired Microturbines Units fired on liquid fuel are subject to a NOx limit of 40 ppm @ 3% O₂ Oxygen correction for turbine emissions is 15%

CATEGORY BACKGROUND MICROTURBINES (DISTILLATE FUEL)


Cost-Effectiveness Analysis


- Staff is recommending an initial BARCT NOx limit of 77 ppm
- □ Identified three distillate fuel turbines, all located at one RECLAIM facility
 - Units are fueled with diesel fuel
- □ Units are rated to 6.46 MMBtu/hr and used as back-up for commercial airplane starter turbines
 - Permit limit of 77 ppm NOx @ 15% O₂
 - Source test results from three units ranged between 65 to 68 ppm






MICROTURBINES (NATURAL GAS) Microturbines <0.3 MW are not currently regulated in any South Coast AQMD Rule Staff's proposal will create a new Rule 1147 category for natural gas fired Microturbines BACT for this category is 9 ppm NOx @ 15% O₂







ALL LIQUID FUEL UNITS (EXCEPT DISTILLATE FUEL MICROTURBINES) Cost-Effectiveness Analysis


- □ Units fired on liquid fuel are subject to a NOx limit of 40 ppm @ 3% O2
- □ Liquid fuel-fired units are generally found on portable combustion sources such as pressure washers and back up fuel for industrial boilers & steam generators
 - Liquid fueled boilers and steam generators are subject to Rule 1146 series
 - Liquid fuel pressure washers up to 550,000 btu/hr are exempt per Rule 219(b)(4)
 - Rule 219 exemption for diesel fuel heaters apply to units below 250,000 btu/hr under Rule 219(b)(3)


33

FURTHER EVALUATION OF RECLAIM DIESEL TAR POT


Cost-Effectiveness Analysis

- Staff identified one diesel fueled tar pot in RECLAIM that would be subject to this category
 - Same unit operates under a non-RECLAIM various locations permit when operated at non-RECLAIM facilities owned by the same operator
 - No other liquid fuel-fired equipment subject to Rule 1147 in non-RECLAIM
- Identified unit is used to patch asphalt at a RECLAIM facility
- □ Unit is equipped with a diesel internal combustion engine rated <50 hp and a diesel fuel-fired thermal fluid heater rated at 420,000 btu/hr
 - Unit was never source tested
- ☐ Equipment usage logs show daily emissions of <1 lb/day
 - Operation logs are required to be kept under RECLAIM reporting





UPDATED STATUS SUMMARY OF BARCT Cost-Effectiveness Analysis ASSESSMENT (CONT'D) **Equipment Equipment** Operating Proposed Current Initial Cost-**BARCT Limit[^]** Category Size **Temperature** Rule Limit[^] **Effectiveness BARCT Limit^** No Additional **Absorption Chillers** ΑII 30 ppm 20 ppm 20 ppm Costs Micro-Turbines No Additional ΑII ΑII N/A 9 ppm* 9 ppm (Natural Gas) Costs Micro-Turbines No Additional ΑII All 40 ppm 40 to 77 ppm* 77 ppm (Distillate Fuel) Costs **Pending Auto-Claves** ΑII ΑII 30 ppm 30 ppm No Additional <1,200°F 40 ppm ΑII 40 ppm 40 ppm All Liquid Fuel-Costs Fired Units No Additional ≥1,200°F ΑII 60 ppm 60 ppm 60 ppm Costs No additional liquid fuel equipment identified other than diesel tar pot and diesel microturbines <0.3 MW Staff propose to maintain existing limits for "All Liquid Fuel-Fired Units" 37 ^ NOx concentrations are corrected to 3% O_2 dry



CONTACTS				
General RECLAIM Questions	Proposed Amended Rules 1147 and 1100	Proposed Rule 1147.1	Proposed Amended Rules 1147, 1100 and Proposed Rule 1147.2	
Gary Quinn, P.E. Program Supervisor	Program Supervisor Air Quality Specialist 909-396-3121 909-396-3319	Shawn Wang Air Quality Specialist 909-396-3319 swang@aqmd.gov	James McCreary Assistant Air Quality	
909-396-3121 gquinn@aqmd.gov		Yanrong Zhu Air Quality Specialist 909-396-3289 yzhu1@aqmd.gov	Specialist 909-396-2451 imccreary@aqmd.gov	
	Gary Quinn, P.E. Program Supervisor 909-396-3121 gquinn@aqmd.gov		Rodolfo Chacon Program Supervisor (W.O.C) 909-396-2726 <u>rchacon@aqmd.gov</u>	